



Finding The Correct Certificate For Your Fire Door

Background Information

All Strongdor fire-rated doors are certified under a certificate of constancy of performance issued from a UKAS accredited, and government approved notified or approved body. The certification body that issues Strongdor's fire-rated certificates is Efectis.

Efectis audit the Strongdor factory production processes to ensure that all doors produced by Strongdor meet the fire scope in the relevant certificate. Strongdor currently has 5 separate fire certificates, and every fire door will be covered by one of these certificates.

How do I know the certificate is genuine?

Every certificate has a certificate number and this can be checked in 3 places to ensure everything is correct.

1. Your door label.
2. The Efectis website for the certificate summary.
3. The Strongdor website for the full certificate.

If the certificate number matches in all 3 places, you can be assured that your fire doors are fully covered by a valid certificate.


How do I find the correct certificate?

Step 1: Check your door label for the certificate number. The example image displayed to the right shows the certificate number '2115' under the notified body number '1812'. (You can verify the government's approval of Efectis to issue a Certificate of Constancy of Performance by searching for "Notified Body Number 1812" on the official government website [here](#).)

Step 2: To verify the certificate number, you can check the Efectis website [here](#). This will confirm the certificate number Strongdor is issued by Efectis and gives a summary of the certificate.

Step 3: Your full certificate can be found and downloaded from the Strongdor website under our Knowledge Library - Certificates.

Fire Certificate: 1812 - CPR - 2099
Fire Certificate: 1812 - CPR - 2115
Fire Certificate: 1812 - CPR - 2029
Fire Certificate: 1812 - CPR - 2116
Fire Certificate: 1812 - CPR - 2118



Certificate reference number